

OFFICE OF THE
LOGAN COUNTY ENGINEER
P.O. BOX 427
1991 COUNTY ROAD 13
BELLEFONTAINE, OH 43311
<http://lceo.us>

SCOTT C. COLEMAN, P.E., P.S.
LOGAN COUNTY ENGINEER

Telephone: (937) 592-2791
Fax: (937) 599-2658

Addendum #1

For

Precast Concrete Box Culvert Bid for Bridge C 28-4.21
August 27, 2019

- One of the “Pre-cast Notes” on page 3 of the Plans errantly states that “All rebar shall be galvanized”. This note shall be replaced with this: “Reinforcement shall consist of welded wire fabric conforming to ASTM Specification A 1064, or Grade 60 rebar, uncoated”.

Michael J. Kerns, P.E.
Assistant Engineer